



**ADDENDUM 1  
REQUEST FOR PROPOSAL (RFP) 11-10  
for  
CNG STATION EQUIPMENT UPGRADES**

December 2, 2011

The purpose of this addendum is to correct typographical errors in RFP and to respond to written questions which were asked either at the Pre-Bid Conference on November 15, 2011 or received by the deadline of November 29, 2011 as stated in RFP. The below questions and answers are hereby incorporated in the RFP/IFB and, if applicable, in any resultant contract. Corrections are labeled "C", questions are labeled "Q" and their respective answers are labeled "A" with each assigned a number for reference purposes.

**CORRECTIONS:**

- C1. Project Specifications should read Appendix A not B**
- C2. Appendix A-Project Specifications, Section 1.01c-Assumptions, paragraph 4**
  - the quantity of the new detectors should read 3.
- C3. Appendix A-Project Specifications, Section 3.05a-Startup, paragraph 2**
  - The paragraph should read as follows: Coordinate with the Owner. The Contractor shall provide seven (7) days advance notice prior to startup.
- C4. Replace Attachment 1-Proposal Form with revised Attachment 1-Proposal Form**
  - Added Addendum 1 Acknowledgement to form.

**QUESTIONS:**

**Q1 Is there to be a replacement of the existing dispensers?**

- A1. Yes-Refer to Appendix A-Project specifications, Section 3.03-Installation, Application and Erection-Dispenser Upgrades, paragraphs D and F**
  - Paragraph D states: *"Replacement of existing NEMA 12 dispenser cabinets with new Stainless Steel dispenser cabinets of like dimensions with all new internal components. The new cabinets shall include all decals and signage required by code, or normally supplied by best industry practice"*.
  - Paragraph F states: *"Replacement of all existing fittings, tubing, instrumentation and valving with new components. The dispensers are to be standardized to one design to the extent allowed by site conditions. It is expected that the internal design of the dispensers will be simplified and more maintenance oriented than the current units"*.

**Q2. Fire Department Notification- Is it required and who is responsible to do the notifying?**

- A2. In accordance with Section 4.36-Federal, State and Local Laws, the contractor shall comply with all applicable federal, state and local laws, statutes and ordinances etc.**



Any cost associated with such compliances shall be reimbursable expenses. The Contractor is responsible for such notifications.

**Q3. What is the amount of the Engineering Cost Estimate?**

**A3. \$75,000.00**

There are no other changes to the RFP/IFB.

**Proposals/Bids are due at GCT by 3:00 PM (PST) December 6, 2011 at 3:00 pm (pst) .**

